Energy performance certificate (EPC)

107 SEREN PARK GARDENS BLACKHEATH SE3 7RR BLACKHEATH SE3 7RR B Certificate number 0300-2023-1070-2699-4451

Property type

Mid-floor flat

Total floor area

53 square metres

Rules on letting this property

Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read <u>guidance for landlords</u> on the regulations and exemptions (<u>https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance</u>).

Energy efficiency rating for this property

This property's current energy rating is B. It has the potential to be B.

See how to improve this property's energy performance.

Score	Energy rating	Current	Potential
92+	Α		
81-91	B	82 I B	821 B
69-80	С		
55-68	D		
39-54	E		
21-38	F		
1-20		G	

The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

The average energy rating and score for a property in England and Wales are D (60).

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	System built, as built, insulated (assumed)	Good
Window	Fully double glazed	Good
Main heating	Community scheme	Good
Main heating control	Flat rate charging, programmer and TRVs	Average
Hot water	Community scheme	Good

Energy performance certificate (EPC) - Find an energy certificate - GOV.UK

Feature	Description	Rating
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	(another dwelling below)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 109 kilowatt hours per square metre (kWh/m2).

What is primary energy use?

Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO2). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO2 emissions.

An average household produces

6 tonnes of CO2

This property produces

1.0 tonnes of CO2

This property's potential production

1.0 tonnes of CO2

By making the <u>recommended changes</u>, you could reduce this property's CO2 emissions by 0.0 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

How to improve this property's energy performance

The assessor did not make any recommendations for this property.

<u>Simple Energy Advice has guidance on improving a property's</u> <u>energy use. (https://www.simpleenergyadvice.org.uk/)</u>



Paying for energy improvements

Find energy grants and ways to save energy in your home. (https://www.gov.uk/improve-energy-efficiency)

Estimated energy use and potential savings

Estimated yearly energy cost for this property

Potential saving

£293

£0

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in how to improve this property's energy performance.

For advice on how to reduce your energy bills visit Simple Energy Advice (https://www.simpleenergyadvice.org.uk/).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Space heating

833 kWh per year

Water heating

1917 kWh per year

Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

You might be able to receive <u>Renewable Heat Incentive payments (https://www.gov.uk/domestic-renewable-heat-incentive)</u>. This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The

estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name

Vincent Piron

Telephone

07516856706

Email

gavrochephotography@gmail.com

Accreditation scheme contact details

Accreditation scheme

Elmhurst Energy Systems Ltd

Assessor ID

EES/023260

Telephone

01455 883 250

Email

enquiries@elmhurstenergy.co.uk

Assessment details

Assessor's declaration

No related party

Date of assessment

Date of certificate

18 March 2021

Type of assessment

RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <u>mhclg.digital-</u><u>services@communities.gov.uk</u>, or call our helpdesk on 020 3829 0748.

Certificate number

0818-8039-6396-7060-7954 (/energy-certificate/0818-8039-6396-7060-7954)

Valid until 8 June 2020 (Expired)