Energy performance certificate (EPC)			
15 Acorn Gardens PLYMOUTH	Energy rating	Valid until:	15 June 2030
PL7 4NJ		Certificate number:	8480-6026-4100-4756-0292
Property type	Т	op-floor flat	
Total floor area	51 square metres		

# Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read <u>guidance for landlords on the regulations and exemptions</u> (<u>https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance</u>).

## **Energy rating and score**

This property's energy rating is C. It has the potential to be C.

See how to improve this property's energy efficiency.

Score	Energy rating		Current	Potential
92+	Α			
81-91	B			
69-80	С		80 C	80 C
55-68	D			
39-54	E			
21-38		F		
1-20		G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D the average energy score is 60

## Breakdown of property's energy performance

#### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, 150 mm loft insulation	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in 83% of fixed outlets	Very good
Floor	(another dwelling below)	N/A
Secondary heating	None	N/A

#### Primary energy use

The primary energy use for this property per year is 115 kilowatt hours per square metre (kWh/m2).

### How this affects your energy bills

An average household would need to spend **£320 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £0 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2020** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

### Heating this property

Estimated energy needed in this property is:

- 1,382 kWh per year for heating
- 1,720 kWh per year for hot water

# Impact on the environment

This property's environmental impact rating is B. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

### **Carbon emissions**

An average household 6 tonnes of CO2 produces

This property produces 1.0 tonnes of CO2

This property's 1.0 tonnes of CO2 potential production

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

### Changes you could make

The assessor did not make any recommendations for this property.

#### Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

#### More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency

# Who to contact about this certificate

#### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Lisa Burgess
Telephone	07521 957943
Email	info@tamarpropertygroup.co.uk

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/023415
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

### About this assessment

Assessor's declaration	No related party
Date of assessment	16 June 2020
Date of certificate	16 June 2020
Type of assessment	RdSAP