

PREDICTED ENERGY ASSESSMENT




Plot S47, 3 Bed,
K, B, WC

Dwelling type: House, Mid-Terrace
Date of assessment: 30/11/2023
Produced by: Henry Knight
Total floor area: 86.02 m²

This document is a Predicted Energy Assessment for properties marketed when they are incomplete. It includes a predicted energy rating which might not represent the final energy rating of the property on completion. Once the property is completed, this rating will be updated and an official Energy Performance Certificate will be created for the property. This will include more detailed information about the energy performance of the completed property.

The energy performance has been assessed using the Government approved SAP2012 methodology and is rated in terms of the energy use per square meter of floor area; the energy efficiency is based on fuel costs and the environmental impact is based on carbon dioxide (CO₂) emissions.



The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO₂) emissions. The higher the rating the less impact it has on the environment.

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.

BUILDING REGULATION COMPLIANCE

Calculation Type: New Build (As Designed)



Property Reference	4907-U528-6864-047	Issued on Date	30/11/2023
Assessment Reference	S47	Prop Type Ref	S305 - Mid (As)
Property	Plot S47, 3 Bed, K, B, WC		
SAP Rating	85 B	DER	16.00
Environmental	88 B	% DER<TER	8.72
CO ₂ Emissions (t/year)	1.09	DFEE	42.82
General Requirements Compliance	Pass	% DFEE<TFEE	11.25

Assessor Details	Mr. Henry Knight, Henry Knight, Tel: 01173183565, Henry.knight@aessc.co.uk	Assessor ID	U528-0001
Client			

SUMMARY FOR INPUT DATA FOR New Build (As Designed)

Criterion 1 – Achieving the TER and TFEE rate

1a TER and DER

Fuel for main heating

Mains gas

Fuel factor

1.00 (mains gas)

Target Carbon Dioxide Emission Rate (TER)

17.53 kgCO₂/m²

Dwelling Carbon Dioxide Emission Rate (DER)

16.00 kgCO₂/m²

-1.53 (-8.7%) kgCO₂/m²

Pass

1b TFEE and DFEE

Target Fabric Energy Efficiency (TFEE)

48.24 kWh/m²/yr

Dwelling Fabric Energy Efficiency (DFEE)

42.82 kWh/m²/yr

-5.4 (-11.2%) kWh/m²/yr

Pass

Criterion 2 – Limits on design flexibility

Limiting Fabric Standards

2 Fabric U-values

Element

Average

Highest

External wall

0.17 (max. 0.30)

0.17 (max. 0.70)

Pass

Party wall

0.00 (max. 0.20)

-

Pass

Floor

0.13 (max. 0.25)

0.13 (max. 0.70)

Pass

Roof

0.11 (max. 0.20)

0.11 (max. 0.35)

Pass

Openings

1.43 (max. 2.00)

1.50 (max. 3.30)

Pass

2a Thermal bridging

Thermal bridging calculated from linear thermal transmittances for each junction

3 Air permeability

Air permeability at 50 pascals

5.00 (design value) m³/(h.m²) @ 50 Pa

Maximum

10.0 m³/(h.m²) @ 50 Pa

Pass

Limiting System Efficiencies

4 Heating efficiency

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.

BUILDING REGULATION COMPLIANCE

Calculation Type: New Build (As Designed)



Main heating system

Boiler system with radiators or underfloor - Mains gas
Data from database
Vaillant ecoFIT sustain 835 VUW 356/6-3 (H-GB)
Combi boiler
Efficiency: 89.3% SEDBUK2009
Minimum: 88.0%

Pass

Secondary heating system

None

5 Cylinder insulation

Hot water storage

No cylinder

6 Controls

Space heating controls

Time and temperature zone control

Pass

Hot water controls

No cylinder

Boiler interlock

Yes

Pass

7 Low energy lights

Percentage of fixed lights with low-energy fittings

100 %

Minimum

75 %

Pass

8 Mechanical ventilation

Continuous extract system (decentralised)

0.1400 0.1200

Specific fan power

0.7

Pass

Criterion 3 – Limiting the effects of heat gains in summer

9 Summertime temperature

Overheating risk (Southern England)

Not significant

Pass

Based on:

Overshading

Average

Pass

Windows facing South East

6.21 m², No overhang

Windows facing North West

4.71 m², No overhang

Air change rate

4.00 ach

Blinds/curtains

None

Criterion 4 – Building performance consistent with DER and DFEE rate

Party Walls

Type

U-value

Filled Cavity with Edge Sealing

0.00 W/m²K

Pass

Air permeability and pressure testing

3 Air permeability

Air permeability at 50 pascals

5.00 (design value) m³/(h.m²) @ 50 Pa

Maximum

10.0 m³/(h.m²) @ 50 Pa

Pass

10 Key features

Party wall U-value

0.00 W/m²K

Roof U-value

0.11 W/m²K

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.

RECOMMENDATIONS

	Typical cost	Typical savings per year	Energy efficiency	Environmental impact	Result
Low energy lights			0	0	Already installed
Solar water heating	£4,000 - £6,000	£92	B 86	B 90	Recommended
Photovoltaic	£3,500 - £5,500	£725	A 96	A 99	Recommended
Wind turbine			0	0	Not applicable
Totals	£7,500 - £11,500	£818	A 96	A 99	

DRF

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.