

# PREDICTED ENERGY ASSESSMENT




Plot S48, 3 Bed,  
K, B, WC

Dwelling type: House, Mid-Terrace  
Date of assessment: 30/11/2023  
Produced by: Henry Knight  
Total floor area: 86.02 m<sup>2</sup>

This document is a Predicted Energy Assessment for properties marketed when they are incomplete. It includes a predicted energy rating which might not represent the final energy rating of the property on completion. Once the property is completed, this rating will be updated and an official Energy Performance Certificate will be created for the property. This will include more detailed information about the energy performance of the completed property.

The energy performance has been assessed using the Government approved SAP2012 methodology and is rated in terms of the energy use per square meter of floor area; the energy efficiency is based on fuel costs and the environmental impact is based on carbon dioxide (CO<sub>2</sub>) emissions.



*This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.*

# BUILDING REGULATION COMPLIANCE

## Calculation Type: New Build (As Designed)



Property Reference	4907-U528-6864-048	Issued on Date	30/11/2023
Assessment Reference	S48	Prop Type Ref	S305-H - Mid (Op)
Property	Plot S48, 3 Bed, K, B, WC		
SAP Rating	85 B	DER	16.00
Environmental	88 B	% DER<TER	8.72
CO <sub>2</sub> Emissions (t/year)	1.09	DFEE	42.82
General Requirements Compliance	Pass	% DFEE<TFEE	11.25

Assessor Details	Mr. Henry Knight, Henry Knight, Tel: 01173183565, Henry.knight@aessc.co.uk	Assessor ID	U528-0001
Client			

### SUMMARY FOR INPUT DATA FOR New Build (As Designed)

#### Criterion 1 – Achieving the TER and TFEE rate

##### 1a TER and DER

Fuel for main heating

Mains gas

Fuel factor

1.00 (mains gas)

Target Carbon Dioxide Emission Rate (TER)

17.53 kgCO<sub>2</sub>/m<sup>2</sup>

Dwelling Carbon Dioxide Emission Rate (DER)

16.00 kgCO<sub>2</sub>/m<sup>2</sup>

-1.53 (-8.7%) kgCO<sub>2</sub>/m<sup>2</sup>

Pass

##### 1b TFEE and DFEE

Target Fabric Energy Efficiency (TFEE)

48.24 kWh/m<sup>2</sup>/yr

Dwelling Fabric Energy Efficiency (DFEE)

42.82 kWh/m<sup>2</sup>/yr

-5.4 (-11.2%) kWh/m<sup>2</sup>/yr

Pass

#### Criterion 2 – Limits on design flexibility

##### Limiting Fabric Standards

##### 2 Fabric U-values

###### Element

###### Average

###### Highest

External wall

0.17 (max. 0.30)

0.17 (max. 0.70)

Pass

Party wall

0.00 (max. 0.20)

-

Pass

Floor

0.13 (max. 0.25)

0.13 (max. 0.70)

Pass

Roof

0.11 (max. 0.20)

0.11 (max. 0.35)

Pass

Openings

1.43 (max. 2.00)

1.50 (max. 3.30)

Pass

##### 2a Thermal bridging

Thermal bridging calculated from linear thermal transmittances for each junction

##### 3 Air permeability

Air permeability at 50 pascals

5.00 (design value)

m<sup>3</sup>/(h.m<sup>2</sup>) @ 50 Pa

Maximum

10.0

m<sup>3</sup>/(h.m<sup>2</sup>) @ 50 Pa

Pass

##### Limiting System Efficiencies

##### 4 Heating efficiency

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.

# BUILDING REGULATION COMPLIANCE

## Calculation Type: New Build (As Designed)



Main heating system

Boiler system with radiators or underfloor - Mains gas  
Data from database  
Vaillant ecoFIT sustain 835 VUW 356/6-3 (H-GB)  
Combi boiler  
Efficiency: 89.3% SEDBUK2009  
Minimum: 88.0%

Pass

Secondary heating system

None

### 5 Cylinder insulation

Hot water storage

No cylinder

### 6 Controls

Space heating controls

Time and temperature zone control

Pass

Hot water controls

No cylinder

Boiler interlock

Yes

Pass

### 7 Low energy lights

Percentage of fixed lights with low-energy fittings

100 %

Minimum

75 %

Pass

### 8 Mechanical ventilation

Continuous extract system (decentralised)

0.1400 0.1200

Specific fan power

0.7

Pass

### **Criterion 3 – Limiting the effects of heat gains in summer**

#### 9 Summertime temperature

Overheating risk (Southern England)

Not significant

Pass

Based on:

Overshading

Average

Pass

Windows facing South East

6.21 m<sup>2</sup>, No overhang

Windows facing North West

4.71 m<sup>2</sup>, No overhang

Air change rate

4.00 ach

Blinds/curtains

None

### **Criterion 4 – Building performance consistent with DER and DFEE rate**

#### Party Walls

Type

U-value

Filled Cavity with Edge Sealing

0.00 W/m<sup>2</sup>K

Pass

#### Air permeability and pressure testing

##### 3 Air permeability

Air permeability at 50 pascals

5.00 (design value) m<sup>3</sup>/(h.m<sup>2</sup>) @ 50 Pa

Maximum

10.0 m<sup>3</sup>/(h.m<sup>2</sup>) @ 50 Pa

Pass

#### 10 Key features

Party wall U-value

0.00 W/m<sup>2</sup>K

Roof U-value

0.11 W/m<sup>2</sup>K

*This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.*

## RECOMMENDATIONS

	Typical cost	Typical savings per year	Energy efficiency	Environmental impact	Result
Low energy lights			0	0	Already installed
Solar water heating	£4,000 - £6,000	£92	B 86	B 90	Recommended
Photovoltaic	£3,500 - £5,500	£725	A 96	A 99	Recommended
Wind turbine			0	0	Not applicable
<b>Totals</b>	<b>£7,500 - £11,500</b>	<b>£818</b>	<b>A 96</b>	<b>A 99</b>	

DRF

*This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.*