


# PREDICTED ENERGY ASSESSMENT

Plot 369, 1bed,  
K, B,  
1


Dwelling type: Flat, End-Terrace  
Date of assessment: 12/05/2023  
Produced by: Eloise Utley  
Total floor area: 50.13 m<sup>2</sup>

This document is a Predicted Energy Assessment for properties marketed when they are incomplete. It includes a predicted energy rating which might not represent the final energy rating of the property on completion. Once the property is completed, this rating will be updated and an official Energy Performance Certificate will be created for the property. This will include more detailed information about the energy performance of the completed property.

The energy performance has been assessed using the Government approved SAP2012 methodology and is rated in terms of the energy use per square meter of floor area; the energy efficiency is based on fuel costs and the environmental impact is based on carbon dioxide (CO<sub>2</sub>) emissions.



The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.



The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO<sub>2</sub>) emissions. The higher the rating the less impact it has on the environment.

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.

# BUILDING REGULATION COMPLIANCE

## Calculation Type: New Build (As Designed)



Property Reference	4907-0015-4290-369	Issued on Date	12/05/2023
Assessment Reference	Plot 369	Prop Type Ref	C 1F 1A (End)
Property	Plot 369, 1bed, K, B, 1		

SAP Rating	84 B	DER	23.26	TER	23.10
Environmental	86 B	% DER<TER	-0.70		
CO <sub>2</sub> Emissions (t/year)	0.98	DFEE	26.92	TFEE	28.85
General Requirements Compliance	Fail	% DFEE<TFEE	6.70		

Assessor Details	Ms. Eloise Utley, Eloise Utley , Tel: 01884 242 050, Eloise.Utley@aessc.co.uk	Assessor ID	T714-0001
Client	Keepmoat, 4290		

### SUMMARY FOR INPUT DATA FOR New Build (As Designed)

#### Criterion 1 – Achieving the TER and TFEE rate

##### 1a TER and DER

Fuel for main heating	Electricity		
Fuel factor	1.55 (electricity)		
Target Carbon Dioxide Emission Rate (TER)	23.10	kgCO <sub>2</sub> /m <sup>2</sup>	
Dwelling Carbon Dioxide Emission Rate (DER)	23.26	kgCO <sub>2</sub> /m <sup>2</sup>	
Excess emissions	0.16 (0.7%)	kgCO <sub>2</sub> /m <sup>2</sup>	Fail

##### 1b TFEE and DFEE

Target Fabric Energy Efficiency (TFEE)	28.85	kWh/m <sup>2</sup> /yr	
Dwelling Fabric Energy Efficiency (DFEE)	26.92	kWh/m <sup>2</sup> /yr	
	-2.0 (-6.9%)	kWh/m <sup>2</sup> /yr	Pass

#### Criterion 2 – Limits on design flexibility

##### Limiting Fabric Standards

##### 2 Fabric U-values

Element	Average	Highest	
External wall	0.16 (max. 0.30)	0.20 (max. 0.70)	Pass
Party wall	0.00 (max. 0.20)	-	Pass
Openings and curtain wall	1.40 (max. 2.00)	1.40 (max. 3.30)	Pass

##### 2a Thermal bridging

Thermal bridging calculated from linear thermal transmittances for each junction

##### 3 Air permeability

Air permeability at 50 pascals	4.00 (design value)	m <sup>3</sup> /(h.m <sup>2</sup> ) @ 50 Pa	
Maximum	10.0	m <sup>3</sup> /(h.m <sup>2</sup> ) @ 50 Pa	Pass

##### Limiting System Efficiencies

##### 4 Heating efficiency

Main heating system	Room heaters - Electric Panel, convector or radiant heaters	
Secondary heating system	None	

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.

# BUILDING REGULATION COMPLIANCE

## Calculation Type: New Build (As Designed)

### 5 Cylinder insulation

Hot water storage	Measured cylinder loss: 1.18 kWh/day Permitted by DBSCG 1.85	Pass
Primary pipework insulated	No primary pipework	

### 6 Controls

Space heating controls	Programmer and appliance thermostats	Pass
Hot water controls	Cylinderstat	Pass

### 7 Low energy lights

Percentage of fixed lights with low-energy fittings	100	%	
Minimum	75	%	Pass

### 8 Mechanical ventilation

Continuous supply and extract system			
Specific fan power	0.59		
Maximum	1.5		Pass
MVHR efficiency	94	%	
Minimum	70	%	Pass

## Criterion 3 – Limiting the effects of heat gains in summer

### 9 Summertime temperature

Overheating risk (Thames Valley)	Slight	Pass
Based on:		
Overshading	Average	
Windows facing East	8.12 m <sup>2</sup> , No overhang	
Air change rate	4.00 ach	
Blinds/curtains	None	

## Criterion 4 – Building performance consistent with DER and DFEE rate

### Party Walls

Type	U-value		
Filled Cavity with Edge Sealing	0.00	W/m <sup>2</sup> K	Pass
Filled Cavity with Edge Sealing	0.00	W/m <sup>2</sup> K	Pass
Filled Cavity with Edge Sealing	0.00	W/m <sup>2</sup> K	Pass

### Air permeability and pressure testing

#### 3 Air permeability

Air permeability at 50 pascals	4.00 (design value)	m <sup>3</sup> /(h.m <sup>2</sup> ) @ 50 Pa	
Maximum	10.0	m <sup>3</sup> /(h.m <sup>2</sup> ) @ 50 Pa	Pass

### 10 Key features

External wall U-value	0.14	W/m <sup>2</sup> K
Party wall U-value	0.00	W/m <sup>2</sup> K
Party wall U-value	0.00	W/m <sup>2</sup> K
Party wall U-value	0.00	W/m <sup>2</sup> K
Door U-value	1.10	W/m <sup>2</sup> K
Door U-value	1.09	W/m <sup>2</sup> K

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.

# RECOMMENDATIONS

	Typical cost	Typical savings per year	Energy efficiency	Environmental impact	Result
Low energy lights			0	0	Already installed
Solar water heating			0	0	Not applicable
Photovoltaic			0	0	Not applicable
Wind turbine			0	0	Not applicable
<b>Totals</b>	<b>£0</b>	<b>£0</b>	<b>B 84</b>	<b>B 86</b>	

**DRAFT**

*This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.*